

UNTERLAGEN ZUM NACHWEIS DER EX-KONFORMITÄT

● 1 - EU-Konformitätserklärung nach dem Konformitätsbewertungsverfahren ATEX 95

Directive ATEX95 refers to ATEX directive 94/9/EG.

The ATEX Directive 2014/34/EU replaced the previous ATEX Directive 94/9/EC which was applicable between 1 July 2013 and 19 April 2016.

As of 20 April 2016, Directive 2014/34/EU, as transposed into the national legislation of the EU Member States, is the sole legal instrument applicable.

This means that our documents refer now to Directive 2014/34/EU.

Declaration of conformity is included in our instruction manual (page 8).

Attached :

- Notice BOYLE-revH - v20190110
- Notice HUTTON-revH - V20190110
- Notice JAMIN-revH - V20190110

● EU-Baumusterprüfbescheinigung für Geräte der Kategorien 1 und 2

BOYLE, JAMIN and HUTTON belong to category 2 for dust and category 3 for gaz.

Attached :

- EU type examination certificate INERIS 15ATEX0005X (file : INERIS 15ATEX0005X - 2D - HUTTON - BOYLE - JAMIN – FUMAT)
- type examination certificate INERIS 15ATEX3002X (file : INERIS 15ATEX3002X - 3G - HUTTON - BOYLE - JAMIN – FUMAT)
- IECEX INE 15.0014X - HUTTON - BOYLE - JAMIN - FUMAT

● • QS-System

Quality assessment report summary

Attached :

- FR_INE_QAR13.0006_05

● Mitteilung der benannten Stelle über das QS-System für die Geräte der Kategorien 1 und 2 :

Attached :

- notification INERIS 04ATEXQ70500655120181205091349

● Betriebsanleitung

Attached :

- Notice BOYLE-revH - v20190110
- Notice HUTTON-revH - V20190110
- Notice JAMIN-revH - V20190110

● Aufschriften und EX-Kennzeichnung

Marking on the product as stated on the mounting instruction (power, flux and current varies according to the type of product) :

<p>xxW / xxxlm 220-240V / 50/60HZ In = xxmA Sous 230VAC</p>	<p>II 3G Ex nA IIC T4 Gc II 2D Ex tb IIIC T65°C Db IP66/IP68 INERIS 15ATEX0005X / INERIS 15ATEX3002X IECEX INE 15.0014X</p>
--	---